



CERTIFICATE OF APPROVAL

No CF 388

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

Allegion (UK) LTD

35 Rocky Lane, Aston Birmingham, B6 5RQ
TEL: 0121 380 2400

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

Briton 1100 Series Overhead
Door Closers referenced 1110,
1110T, 1120B, 1130B, 1130B.T,
1130B.TE

TECHNICAL SCHEDULE

TS 34 - The Contribution Of
Controlled Door Closing
Devices And Accessories To
Fire Resisting Doorsets

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan
Certification Manager

Issued: 11th November 2019
Valid to: 10th November 2024

Page 1 of 6



CERTIFICATE No CF 388 ALLEGION (UK) LIMITED

BRITON 1100 SERIES OVERHEAD DOOR CLOSERS

1. Briton 1100 series closers are overhead mounted door closing devices. The approval relates to the following specific closers:

	Link-arms			Slide arms			
	Projecting arm (Fig. 1) <i>Body door mounted on pull face</i>	Projecting arm (Fig. 61) <i>Body transom mounted on push face</i>	Parallel arm (Fig. 6) <i>Body door mounted on push face</i>	Body door mounted on pull face	Body transom mounted on push face	Body door mounted on push face	Body transom mounted on pull face
Briton 1110	✓	✓	✓	✗	✗	✗	✗
Briton 1110T	✗	✗	✗	✓	✓	✗	✓
Briton 1120B	✓	✓	✓	✗	✗	✗	✗
Briton 1130B	✓	✗	✓	✗	✗	✗	✗
Briton 1130B.T	✗	✗	✗	✓	✓	✗	✓
Briton 1130B.TE	✗	✗	✗	✓	✗	✗	✗

Key: ✓ - approved ✗ - Not approved

Note: Where alternative arms for non-fire applications are included within the packaging, the use of these components on fire resisting door assemblies will invalidate the certification.

2. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
3. This approval relates to their use with the following door assemblies:-

Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames having a fire resistance up to 120 minutes (Code ITT).

Latched and unlatched, door assemblies consisting of metal faced and edged leaves in metal frames, fully-insulated for the required classification period, with or without intumescent sealing, and having a fire resistance up to 240 minutes (Codes MM & IMM)



CERTIFICATE No CF 388 ALLEGION (UK) LIMITED

BRITON 1100 SERIES OVERHEAD DOOR CLOSERS

4. The closers are approved on the basis of:
 - i) Initial type testing to EN1154, EN 1155 and BS EN 1634-1
 - ii) An appraisal against TS34
 - iii) Certification of quality management system.
 - iv) Inspection and surveillance of factory production control
 - v) On-going audit testing in accordance with EN 1154 requirements
5. The closers shall be fixed with screws supplied by the closer manufacturer. Bolt-through fixings shall not be used.
6. Where the closers are fitted to door leaves or frames that are manufactured from mineral composite-based materials, or low-density cellulosic- based material, the door assembly shall have previously been shown capable of accommodating the installation of closers at the head of the doorset, without detriment to the door assembly's performance.
7. This approval is applicable only to the specified closers when mounted in the applications stated above and under the classification codes section of this certificate and used with door assemblies of proven fire resistance (as defined in BS EN 1634-1 or BS 476: Part 22: 1987) and having power ratings appropriate to the leaf sizes subject to a minimum size 3 (as specified in BS EN 1154).
8. The approval relates to on-going production. Product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.



CERTIFICATE No CF 388 ALLEGION (UK) LIMITED

BRITON 1100 SERIES OVERHEAD DOOR CLOSERS

9. The following table shows acceptable doorset types and fire resistance periods:

Class	Approved Door Type				
	MM	IMM	ITT	ITM	ITC
FD20	✓*	✓*	✓	✓*	✓
FD30	✓*	✓*	✓	✓*	✓
FD60	✓*	✓*	✓	✓*	✓
FD120	✓*	✓*	✓	✓*	✓
FD240	✓*	✓*	✗	✗	✗
E 20	✗	✗	✓	✓*	✓
EI 20	✓*	✓*	✓	✓*	✓
E 30	✗	✗	✓	✓*	✓
EI 30	✓*	✓*	✓	✓*	✓
E 60	✗	✗	✓	✓*	✓
EI 60	✓*	✓*	✓	✓*	✓
E 90	✗	✗	✓	✓*	✓
EI 90	✓*	✓*	✓	✓*	✓
E 120	✗	✗	✓	✓*	✓
EI 120	✓*	✓*	✓	✓*	✓
E 240	✗	✗	✗	✗	✗
EI 240	✓*	✓*	✗	✗	✗

Key:

- ✓ - approved
- ✗ - Not approved
- ✓* - Fully-insulated steel-based doors and frames only

CERTIFICATE No CF 388 ALLEGION (UK) LIMITED

BRITON 1100 SERIES OVERHEAD DOOR CLOSERS

10. Doors are classified as the following types:

Type MM - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that do not contain intumescent materials in the frame to leaf gap.

Type IMM - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that contain intumescent materials in the frame to leaf gap.

Type ITT - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in timber frames

Type ITM - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in metal frames.

Type ITC - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in proprietary composite frames, of which the principal material is other than timber or metal but which may include any other materials.

Scope of Approval:

- Doors may not include uninsulated glass above 20% of their total area.
- The closer may not be fitted to timber doorsets without leaf/frame edge intumescent protection to the door edge or frame rebate.
- Closers are only approved for use with steel-based doors and frames that are fully-insulated for the required classification period.
- Mechanical Hold open option is not approved
- Closers are approved for use with the 'Trimplate', 'Classic Cover' and 'Soft Line Cover' options in all applications.

Classification codes

This approval provides the following classifications for the closer models listed below:

Briton 1110 – Projecting arm figure 1 and transom mounted Figure 61:

3	8	4 2	1	1	3
---	---	--------	---	---	---

Briton 1110 – Parallel arm Figure 6:

3	8	3	1	1	3
---	---	---	---	---	---



CERTIFICATE No CF 388 ALLEGION (UK) LIMITED

BRITON 1100 SERIES OVERHEAD DOOR CLOSERS

Classification codes - Continued

Briton 1110T: Slide arm - Body door mounted pull face, transom mounted pull face and transom mounted push face:

4	8	3	1	1	3
---	---	---	---	---	---

Briton 1120B - Projecting arm figure 1 and transom mounted Figure 61, and parallel arm Figure 6:

4	8	4 2	1	1	3
---	---	--------	---	---	---

Briton 1130B – Projecting arm figure 1:

4	8	6 2	1	1	3
---	---	--------	---	---	---

Briton 1130B - Parallel arm Figure 6:

4	8	5 2	1	1	3
---	---	--------	---	---	---

Briton 1130B.T Slide arm - Body door mounted pull face, transom mounted pull face and transom mounted push face:

4	8	4 2	1	1	3
---	---	--------	---	---	---

Briton 1130B.TE - Slide arm - Body door mounted pull face:

3	8	4 2	1	1	3
---	---	--------	---	---	---

Note: power ratings shall be appropriate to the leaf sizes subject to a minimum size 3 (as specified in BS EN 1154).

Further Information

Further information regarding the details contained in this certificate may be obtained from Allegion (UK) Limited (Tel: 0121 380 2400).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).