
CERTIFICATE OF APPROVAL
No CF 118

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

DORMA UK LTD

Wilbury Way, Hitchin, Hertfordshire SG4 0AB

Tel: 01462 477600

Fax: 01462 477601

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

**Dorma TS 83 and TS 89 F
Overhead Mounted Door
Closers**

TECHNICAL SCHEDULE

**TS 34 - The Contribution Of
Controlled Door Closing
Devices And Accessories To
Fire Resisting Doorsets**

**Signed and sealed for and on behalf of Exova (UK) Limited trading as
Warrington Certification**



**Paul Duggan
Certification Manager**



Issued: 3rd February 1992
Revised: 20th August 2018
Valid to: 2nd February 2022

Page 1 of 6



CERTIFICATE No CF 118

DORMA UK LTD

DORMA TS 83 AND TS 89 F OVERHEAD MOUNTED DOOR CLOSERS

4. This approval relates to its use with the following door assemblies:-

Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames having a fire resistance up to 120 minutes (Code ITT).

Latched and unlatched, door assemblies consisting of metal faced and edged leaves in metal frames, fully-insulated for the required classification period, with or without intumescent sealing, and having a fire resistance up to 240 minutes (Codes MM & IMM)

Latched and unlatched, door assemblies consisting of metal faced and edged leaves in metal frames, uninsulated for the required classification period, with or without intumescent sealing, and having a fire resistance up to 240 minutes (Codes MM & IMM) with closers fitted to the fire risk face only*

Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in fully-insulated steel frames having a fire resistance up to 120 minutes (Code ITM)

**The closer must not be used in this application where a specific direction of fire exposure for the doorset cannot be identified*

5. The closers shall be fixed with screws supplied by the closer manufacturer. Bolt-through fixings shall not be used.
6. Where the closers are fitted to door leaves or frames that are manufactured from mineral composite-based materials, or low-density cellulosic-based material, the door assembly shall have previously been shown capable of accommodating the installation of closers at the head of the doorset, without detriment to the door assembly's performance.
7. This approval is applicable only to the specified closers when mounted in the applications stated above and under the classification codes section of this certificate and used with door assemblies of proven fire resistance (as defined in BS EN 1634-1 or BS 476: Part 22: 1987) and having power ratings appropriate to the leaf sizes subject to a minimum size 3 (as specified in BS EN 1154).
8. The approval relates to on-going production. The product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

CERTIFICATE No CF 118

DORMA UK LTD

DORMA TS 83 AND TS 89 F OVERHEAD MOUNTED DOOR CLOSERS

9. The following table shows acceptable doorsets types and fire resistance periods:

Class	Approved Door Type				
	MM	IMM	ITT	ITM	ITC
FD20	✓*#	✓*#	✓	✓*	✓
FD30	✓*#	✓*#	✓	✓*	✓
FD60	✓*#	✓*#	✓	✓*	✓
FD120	✓*#	✓*#	✓	✓*	✓
FD240	✓*#	✓*#	✗	✗	✗
E 20	✓#	✓#	✓	✓*	✓
EI 20	✓*	✓*	✓	✓*	✓
E 30	✓#	✓#	✓	✓*	✓
EI 30	✓*	✓*	✓	✓*	✓
E 60	✓#	✓#	✓	✓*	✓
EI 60	✓*	✓*	✓	✓*	✓
E 90	✓#	✓#	✓	✓*	✓
EI 90	✓*	✓*	✓	✓*	✓
E 120	✓#	✓#	✓	✓*	✓
EI 120	✓*	✓*	✓	✓*	✓
E 240	✓#	✓#	✗	✗	✗
EI 240	✓*	✓*	✗	✗	✗

Key:

- ✓ - approved
- ✗ - Not approved
- ✓* - Fully-insulated steel-based doors and frames only
- ✓# - Fitted to the fire risk face only of Uninsulated steel-based doors and frames only
- ✓*# - Fitted to Fully-insulated steel-based doors and frames, or the fire risk face only of Uninsulated steel-based doors and frames

CERTIFICATE No CF 118

DORMA UK LTD

DORMA TS 83 AND TS 89 F OVERHEAD MOUNTED DOOR CLOSERS

10. Doors are classified as the following types:

Type MM - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that do not contain intumescent materials in the frame to leaf gap.

Type IMM - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that contain intumescent materials in the frame to leaf gap.

Type ITT - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in timber frames

Type ITM - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in metal frames.

Type ITC - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in proprietary composite frames, of which the principal material is other than timber or metal but which may include any other materials.

Scope of Approval:

- Doors may not include uninsulated glass above 20% of their total area.
- The closers may not be fitted to doorsets incorporating timber leaves without leaf/frame edge intumescent protection.
- Closers are approved for use on both sides of steel-based doors and frames that are fully-insulated for the required classification period.
- For uninsulated steel-based doors and frames the closers shall be fitted to the fire risk face only. **The closer must not be used in this application where a specific direction of fire exposure for the doorset cannot be identified**
- Mechanical Hold open option is not approved.

Classification codes

The approval provides the following classification:

TS 83 BC EN7 when mounted in projecting arm (Figure 1) and transom mount (Figure 61):

4	8	7	1	1	4
---	---	---	---	---	---

TS 83 BCDC EN3-6 and TS 83 BC EN3-6 when mounted in projecting arm (Figure 1) and transom mount (Figure 61):

CERTIFICATE No CF 118
DORMA UK LTD

4	8	6 3	1	1	4
---	---	--------	---	---	---

DORMA TS 83 AND TS 89 F OVERHEAD MOUNTED DOOR CLOSERS

Classification codes – Cont'd

TS 83 BCDC EN2-5 and TS 83 BC EN2-5 when mounted in projecting arm (Figure 1) and transom mount (Figure 61):

4	8	5 3	1	1	4
---	---	--------	---	---	---

TS 83 BCDC EN2-5 and TS 83 BC EN2-5 when mounted in parallel arm (Figure 6):

4	8	4 3	1	1	4
---	---	--------	---	---	---

TS 83 BCDC EN3-6 and TS 83 BC EN3-6 when mounted in parallel arm (Figure 6):

4	8	5 3	1	1	4
---	---	--------	---	---	---

TS 89 F when mounted in projecting arm (Figure 1):

4	8	6 3	1	1	3
---	---	--------	---	---	---

Further Information

Further information regarding the details contained in this data sheet may be obtained from Dorma UK Limited (Tel: 01462 477600).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).