Accessories

MAINS 230V~

Surface Mount Pattress

Model Ei 157

- Surface mount Pattress
- For use with Ei150 series Smoke and Heat Alarms
- Facilitates bulky wiring and conduits



Product Description

The Ei157 Pattress is designed to facilitate installation of bulky wiring and conduits.

The Ei157 Pattress is designed to be used in conjunction with Ei151TL/153/154TL/156TL/156TLH Smoke and Heat Alarms.

The Ei157 Pattress is designed so that any of the alarms listed above will fit on top of the Ei157 (the Ei157 is specifically designed so that such alarms will screw directly to the Ei157).

The Ei157 Pattress must only be used with one of the Smoke/Heat Alarms listed above – otherwise the unit will not comply with the mandatory safety regulations.

Operation

- Mount the unit in accordance with the siting instructions in the Smoke/Heat Alarm instruction leaflet
- After connecting all of the relevant wiring, simply screw the Smoke/Heat Alarm to the top of the Pattress



Shannon Free Zone, Shannon, Co. Clare, Ireland. Ph.+353 61 471277 Fx.+353 61 471053 Email. eielectronics@eiltd.ie

Web: www.eielectronics.com

Model Ei157

Technical Specification

Supply Voltage: 240V AC Fixing:

Battery back up: No battery back up Plastic material: UL94VO flame retardant


Humidity Range: 0% to 90% Relative Humidity **Weight:** 100g

Warranty: 5 year (limited) warranty **Interconnect:** Up to 12 interconnected

Ei150/151TL/153/154TL/155/156T L/156TLH smoke or heat alarms, along with an EI158R relay base

Specifications are subject to change

Installation



Important Precaution:

Screw fixings supplied

Do not install the actual smoke/heat alarm itself in new or renovated buildings until all work is completed (including floor coverings) and the building has been fully cleaned. The wiring can be installed when appropriate. (Excessive dust and debris from building work can contaminate the smoke chamber and cause problems, and it will also invalidate the guarantee). If it must be installed, cover it completely, particularly around the edges, with a dust cover (eg. a plastic bag), until all cleaning is finished... Connect wires to the unit as in wiring diagram. All wiring must comply with local codes.

Be very careful about correctly wiring the alarms as mixing Live and Neutral will blow/damage interconnected alarms



Shannon Free Zone, Shannon, Co. Clare, Ireland. Ph.+353 61 471277 Fx.+353 61 471053

Email. eielectronics@eiltd.ie Web: www.eielectronics.com