



---

## **CERTIFICATE OF APPROVAL No CF 144**

---

*This is to certify that, in accordance with  
CERTIFIRE's Rules for Certification  
The undermentioned products of*

### **GEZE LIMITED**

**Blenheim Way, Fradley Park, Lichfield, WS13 8SY  
Tel: 01543 443000 Fax: 01543 443021**

Have been assessed against the requirements of the Technical Schedule(s)  
denoted below and are approved for use subject to the conditions  
appended hereto:

---

#### **CERTIFIED PRODUCTS**

**TS1000, TS1200, TS1500  
and TS1500 BC  
Overhead Door Closers**

#### **TECHNICAL SCHEDULE**

**TS 34 - The Contribution Of  
Controlled Door Closing  
Devices And Accessories  
To Fire Resisting Doorsets**

**Signed and sealed for and on behalf of CERTIFIRE**

Sir Ken Knight  
Chairman - Management Council

Issued: 1<sup>st</sup> May 1997  
Reissued: 17<sup>th</sup> August 2006  
Revised: 16<sup>th</sup> July 2008  
Valid to: 16<sup>th</sup> August 2011

Page 1 of 4



Only valid when authentic  
Seal is in place

**CERTIFIRE**



---

## CERTIFICATE No CF 144

### GEZE UK

---

#### TS1000, TS1200, TS1500 and TS1500 BC OVERHEAD DOOR CLOSERS

1. This approval relates to Geze TS1000, TS1200, TS1500 and TS1500 BC closers which are overhead mounted door closing devices.
2. This certification is designed to demonstrate compliance of the product or system specifically with Approved Document B (England and Wales), Section D of the Technical Standards (Scotland) and Technical Booklet E (N. Ireland). If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.
3. This approval relates to their use with the following door assemblies:-  

**Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames having a fire resistance up to 120 minutes (CERTIFIRE Code - ITT).**
4. The closers are approved on the basis of:
  - i) Initial type testing to EN1154 and BS EN 1634-1: 2000
  - ii) An appraisal against TS34
  - iii) Certification of quality management system to ISO 9001: 2000.
  - iv) Inspection and surveillance of factory production control
  - v) Ongoing audit testing in accordance with EN 1154 requirements
5. This approval is applicable only to the specified closers used with door assemblies of proven fire resistance (as defined in BS EN 1634-1: 2000 or BS 476: Part 22: 1987) and having power ratings appropriate to the leaf sizes subject to a minimum size 3 (as specified in BS EN 1154).
6. The approval relates to on going production. Product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

A handwritten signature in black ink, appearing to be the initials "KJM" followed by a stylized flourish.




---

**CERTIFICATE No CF 144**  
**GEZE UK**

---

**TS1000, TS1200, TS1500 and TS1500 BC OVERHEAD DOOR CLOSERS**

7. The following tables show acceptable doorset types and fire resistance periods:

<b>Approved Door Type</b>							
<b>Class</b>	<b>IMM</b>	<b>MM</b>	<b>TT</b>	<b>ITT</b>	<b>ITM</b>	<b>ITC</b>	<b>TM</b>
<b>FD20</b>	<b>x</b>	<b>x</b>	<b>x</b>	<b>✓</b>	<b>x</b>	<b>✓</b>	<b>x</b>
<b>FD30</b>	<b>x</b>	<b>x</b>	<b>x</b>	<b>✓</b>	<b>x</b>	<b>✓</b>	<b>x</b>
<b>FD60</b>	<b>x</b>	<b>x</b>	<b>x</b>	<b>✓</b>	<b>x</b>	<b>✓</b>	<b>x</b>
<b>FD120</b>	<b>x</b>	<b>x</b>	<b>x</b>	<b>✓</b>	<b>x</b>	<b>✓</b>	<b>x</b>
<b>FD240</b>	<b>x</b>	<b>x</b>	<b>x</b>	<b>x</b>	<b>x</b>	<b>x</b>	<b>x</b>
<b>E 20</b>	<b>x</b>	<b>x</b>	<b>x</b>	<b>✓</b>	<b>x</b>	<b>✓</b>	<b>x</b>
<b>EI 20</b>	<b>x</b>	<b>x</b>	<b>x</b>	<b>✓</b>	<b>x</b>	<b>✓</b>	<b>x</b>
<b>E 30</b>	<b>x</b>	<b>x</b>	<b>x</b>	<b>✓</b>	<b>x</b>	<b>✓</b>	<b>x</b>
<b>EI 30</b>	<b>x</b>	<b>x</b>	<b>x</b>	<b>✓</b>	<b>x</b>	<b>✓</b>	<b>x</b>
<b>E 60</b>	<b>x</b>	<b>x</b>	<b>x</b>	<b>✓</b>	<b>x</b>	<b>✓</b>	<b>x</b>
<b>EI 60</b>	<b>x</b>	<b>x</b>	<b>x</b>	<b>✓</b>	<b>x</b>	<b>✓</b>	<b>x</b>
<b>E 90</b>	<b>x</b>	<b>x</b>	<b>x</b>	<b>✓</b>	<b>x</b>	<b>✓</b>	<b>x</b>
<b>EI 90</b>	<b>x</b>	<b>x</b>	<b>x</b>	<b>✓</b>	<b>x</b>	<b>✓</b>	<b>x</b>
<b>E 120</b>	<b>x</b>	<b>x</b>	<b>x</b>	<b>✓</b>	<b>x</b>	<b>✓</b>	<b>x</b>
<b>EI 120</b>	<b>x</b>	<b>x</b>	<b>x</b>	<b>✓</b>	<b>x</b>	<b>✓</b>	<b>x</b>
<b>E 240</b>	<b>x</b>	<b>x</b>	<b>x</b>	<b>x</b>	<b>x</b>	<b>x</b>	<b>x</b>
<b>EI 240</b>	<b>x</b>	<b>x</b>	<b>x</b>	<b>x</b>	<b>x</b>	<b>x</b>	<b>x</b>

See CERTIFIRE Technical Schedules for designation of doorset types i.e. ITT etc.



---

**CERTIFICATE No CF 144  
GEZE UK**

---

**TS1000, TS1200, TS1500 and TS1500 BC OVERHEAD DOOR CLOSERS**

Limitations of Approval:

Door leaves may not include uninsulated glass above 20% of their total area.  
The closers may not be fitted to timber doorsets without intumescent protection.

**Classification codes**

This approval provides the following classifications for the closers listed above:

4	8	4 3	1	1	4
---	---	--------	---	---	---

**TS1000, TS1200**

4	8	4 3	1	1	4
---	---	--------	---	---	---

**TS1500, TS1500 BC**

**Further Information**

Further information regarding the details contained in this data sheet may be obtained from GEZE UK (Tel: 01543 443000).

Further information regarding the CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777)

A handwritten signature in black ink, appearing to read "G. Smith", is located below the page number.