

P50 Service-Free Fire Extinguisher Visual Inspection Record

Complete a thorough visual inspection on each P50 Service-Free Fire Extinguishers every year using the steps below as a guide. Use the table on the reverse to record your inspections.

1. Visual Inspections



Check body of extinguisher for damage.



Check tamper seal is not broken & handle is not bent.



Inspect the base ring for damage or cracks.



Examine the hose. Ensure nothing is blocking the nozzle.



Wipe extinguisher down with warm soapy water.



Use the red magnet provided (base of extinguisher) to ensure that the needle on both gauges moves freely.


2. Check Date



Note the colour of the plug next to the nozzle holder.



Consult the chart on the back of the extinguisher to identify the year of manufacture.



The age of the extinguisher should be within 10 years of manufacture or last factory refurbishment.

3.Record Keeping

Once you have completed the extinguisher check, sign the back of the extinguisher to verify against the correct year. Record the inspection in your fire safety log book with this completed checklist, and store for future reference.

Extinguisher ID / Location	Extinguisher Checked (tick)	Check recorded on the extinguisher (tick)	Inspector Initial

Notes:

Name of Inspector:

Date:

Signature:

Safelincs P50 Service-Free Fire Extinguishers have a 10 year warranty. If you discover any issues with your P50 Extinguishers during the inspection, please contact your designated responsible individual.

KEEP THIS COMPLETED ANNUAL INSPECTION CHECKLIST WITH YOUR FIRE SAFETY RECORDS

3. Record Keeping (extra sheet)

[illegible]