

### CERTIFICATE OF APPROVAL No CF 390

This is to certify that, in accordance with TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

### **ALLEGION (UK) LIMITED**

35 Rocky Lane, Aston, Birmingham, B6 5RQ, United Kingdom Tel: +44 (0) 121 380 2400

Have been assessed against the requirements of the Technical Schedule(s) denoted below and are approved for use subject to the conditions appended hereto:

CERTIFIED PRODUCT
Briton 121CE.XXX Overhead
Door Closers

TECHNICAL SCHEDULE
TS 34 - The Contribution Of
Controlled Door Closing
Devices And Accessories To
Fire Resisting Doorsets

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan

**Certification Manager** 







#### **BRITON 121CE.XXX OVERHEAD DOOR CLOSERS**

- 1. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
- 2. This approval relates to the following overhead mounted door closing devices and configurations:

	Link-arms			Slide arms			
	Projecting arm (Fig. 1) Body door mounted on pull face	Projecting arm (Fig. 61) Body transom mounted on push face	Parallel arm (Fig. 6) Body door mounted on push face	Body door mounted on pull face	Body transom mounted on push face	Body door mounted on push face	Body transom mounted on pull face
121CE.XXX	✓	✓	✓	*	*	×	×

**Key:** ✓ - approved

Not approved

Note: Where alternative arms for non-fire applications are included within the packaging, the use of these components on fire resisting door assemblies will invalidate the certification.

3. This approval relates to their use with the following door assemblies: -

Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames having a fire resistance up to 120 minutes (CERTIFIRE Code - ITT)

- 4. The closer is approved on the basis of:
  - i) Initial type testing to EN1154 and BS EN 1634-1.
  - ii) An appraisal against TS34
  - iii) Inspection of quality management system
  - iv) Inspection and surveillance of factory production control
  - v) Ongoing audit testing in accordance with EN 1154 requirements
- 5. This approval is applicable only to the specified closers when mounted in the applications stated above and under the classification codes section of this certificate and used with door assemblies of proven fire resistance (as defined in BS EN 1634-1 or BS 476: Part 22: 1987) and having power ratings appropriate to the leaf sizes subject to a minimum size 3 (as specified in BS EN 1154).

Page 2 of 6 Signed J/165

Pol agg-



#### **BRITON 121CE.XXX OVERHEAD DOOR CLOSERS**

- 6. The closers shall be fixed with screws supplied by the closer manufacturer. Bolt-through fixings shall not be used.
- 7. Where the closers are fitted to door leaves or frames that are manufactured from mineral composite-based materials, or low-density cellulosic- based material, the door assembly shall have previously been shown capable of accommodating the installation of closers at the head of the doorset, without detriment to the door assembly's performance.
- 8. ITT 30 and 60 doorsets shall be installed in accordance with BS 8214.
- 9. The approval relates to on-going production. The product and/or its immediate packaging are identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

Page 3 of 6 Signed J/165

Pol ligg-



#### **BRITON 121CE.XXX OVERHEAD DOOR CLOSERS**

10. The following tables show acceptable doorset types and fire resistance periods:

	Approved Door Type					
Class	ММ	IMM	ITT	ITM		
FD20	×	×	✓	×		
FD30	×	×	✓	×		
FD60	×	×	✓	×		
FD120	×	×	✓	×		
FD240	×	×	×	×		
E 20	×	×	✓	×		
EI 20	×	×	✓	×		
E 30	×	×	✓	×		
EI 30	×	×	✓	×		
E 60	×	×	✓	×		
EI 60	×	×	✓	×		
E 90	×	×	✓	×		
EI 90	×	×	✓	×		
E 120	×	×	✓	×		
EI 120	×	×	✓	×		
E 240	×	×	×	×		
EI 240	×	×	×	×		

#### Kev:

✓ - approved

Not approved

Page 4 of 6 Signed J/165

Pol lyg-



#### **BRITON 121CE.XXX OVERHEAD DOOR CLOSERS**

11. Doors are classified as the following types:

**Code ITT** - 20 minute to 120 minute doorsets containing intumescent seals and consisting of timber faced and edged leaves with timber, cellulosic or mineral cores, hung in timber-based frames.

**Code ITM** - 20 minute to 120 minute doorsets containing intumescent seals and consisting of timber faced and edged leaves with timber, cellulosic or mineral cores, hung in steel frames.

**Code MM** - 20 minute to 120 minute doorsets consisting of uninsulated or insulated predominantly steel leaves, hung in steel frames without intumescent seals.

**Code IMM** - 20 minute to 120 minute doorsets consisting of uninsulated or insulated predominantly steel leaves, hung in steel frames with intumescent seals.

#### **Scope of Approval:**

- Doors may not include uninsulated glass above 20% of their total area. Uninsulated glass shall not be included directly beneath the door closer body.
- The closers may not be fitted to timber doorsets without perimeter intumescent fire seals to the frame rebate or door edge.
- Closers are approved with and without covers.
- Mechanical Hold open option is not approved.
- The following functions are supported by this certification:

Application	Latch Control	Backcheck	Delayed- Action
Projecting arm - Fig. 1 & Fig. 61	Yes	No	No
Parallel arm - Fig. 6	No	No	No

Page 5 of 6 Signed J/165

Pol ligg-



#### **BRITON 121CE.XXX OVERHEAD DOOR CLOSERS**

#### **Classification code**

Projecting arm (Figure 1) application:

4	8	3	1	1	3
---	---	---	---	---	---

Projecting arm (Figure 61) and parallel arm (Figure 6) applications:

3	8	3	1	1	3
---	---	---	---	---	---

Note: power ratings shall be appropriate to the leaf sizes subject to a minimum size 3 (as specified in BS EN 1154).

#### **Further Information**

Further information regarding the details contained in this certificate may be obtained from Allegion (UK) Limited (Tel: 0121 380 2400).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

Page 6 of 6 Signed J/165

fol lagg-