

UL-EU CERTIFICATE

Certificate No. UL-EU-00834-A2-CPR
Page 1/157
Date of Issue 2015-09-09
Revised 2021-12-16

Certificate Holder Astroflame Fireseals LTD
Unit 8, I.O Centre,
Stephenson Road,
Segensworth,
Fareham,
PO15 5RU

Manufacturer A/008

Certified Product Type Fire Stop – Coated Board
Product Trade Name Astro Batt and Coating
Trademark N/A
Rating/Classification See Appendix

Harmonised Technical Specifications ETAG 026-2 / EN 13501-2 / EN 13501-3
Expiry date 2025-09-08



A handwritten signature in blue ink, appearing to read 'Chris Miles'.

Authorized Certification Decision Maker
Chris Miles

This is to certify that representative samples of the Certified Product listed above have been investigated by Underwriters Laboratories to the Standard(s) indicated on this Certificate, in accordance with the UL Global Services Agreement and the UL-EU Mark Service Terms and Conditions ("Agreement"). The Certificate Holder is entitled to use the UL-EU Mark for the Certified Product listed on the certificate and manufactured at the production site(s) listed, in accordance with the terms of the Agreement. Only those products bearing the UL-EU Mark for Europe should be considered as being covered by UL's UL-EU Mark Service. This Certificate shall remain valid through the Expiration date, unless a Standard identified on this Certificate is amended or withdrawn prior to that date or there is a non-compliance with the Agreement.



Appendix UL-EU CERTIFICATE

Certificate No. UL-EU-00834-A2-CPR
Page 2/157
Date of Issue 2015-09-09

This certificate relates to the use of Astro Batt and Coating for fire stopping where services penetrate floors and walls. The detailed scope is given in pages 3 to 156 of this Certificate. This shows the thickness and acceptable dimensions, substrates and orientations required to provide fire resistance periods of up to 120 minutes (EI 120).

The product is certificated on the basis of:

- i) Inspection and surveillance of factory production control by UL
- ii) Fire resistance test data in accordance with 1366-3: 2009 & EN 1366-1: 2000
- iii) Classification in accordance with EN 13501-2 & EN 13501-3
- iv) Durability and Servicability as defined in ETAG 026-2

The durability class of Astro Batt and Coating is Z₁ -intended for use at internal conditions with high humidity, excluding temperatures below 0°C

VOC test report – Indoor Air Comfort GOLD[®] referenced – eurofins 392-2017-00008801_A_EN, is also available.

Fire resisting & smoke extraction ducts penetrating the Astro Batt and Coating shall be classified (EN13501-3/4) for the required performance period, in addition to the details given on page 156.

