

Declaration of Performance
**CONSTRUCTION PRODUCTS REGULATION 2011
DECLARATION OF PERFORMANCE**
No. UK-DC-DOP-002

1. Unique identification code of the product-type:

Briton 2004 Overhead Door Closer

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR:

Briton 2004

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

For use on fire and smoke compartmentation doors

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

**Allegion
Bescot Crescent
Walsall
WS1 4DL**

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

N/A

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

System 1

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

**EN 1154: 1996: A1: 2002
Notified Certification body No.1121 performed the type testing and issued test reports.**

8. European Technical Assessment:

N/A

9. Declared performance

Essential characteristics	Performance	Harmonised technical specification
Self closing 5.2.1 General Application 5.2.2 Durability 5.2.3 Closing moment 5.2.4 Opening moment 5.2.5 Efficiency	Door Mount Pull (Fig 1) Transom Mount Push (Fig 61) 500,000 Pass size 4 Pass size 4 >60% size 4	EN 1154: 1996: A1: 2002

5.2.6 Closing time	Pass	
5.2.7 Angles of operation	Grade 4, 180°	
5.2.8 Overload performance	Pass	
5.2.9 Temperature dependence	-15°C to +40°C	
5.2.10 Fluid leakage	Pass	
5.2.11 Damage	Pass	
5.2.12 Latch control	Pass	
5.2.13 Backcheck	n/a	
5.2.14 Delayed Action	n/a	
5.2.15 Adjustable closing force	Pass	
5.2.18 Fire / smoke doors	Pass	
Essential characteristics	Performance	Harmonised technical specification
<u>Durability of Self Closing</u>		
5.2.2 Durability	500,000	
5.2.17.1 corrosion	Grade 3 (96 hours)	
5.2.17.2 corrosion	Pass	EN 1154: 1996: A1: 2002
<u>Dangerous Substances</u>		
<u>Annex ZA3</u>	Pass	

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.
Signed for and on behalf of the manufacturer by:

Chris Crampton
Controller - Unitary EMEIA, Finance and Accounting



Allegion,
Bescot Crescent,
Walsall,
WS1 4DL

02nd December 2013