

**Declaration of performance**
**CONSTRUCTION PRODUCTS REGULATION 2011  
DECLARATION OF PERFORMANCE**
**No. UK-DC-DOP-HOD-004**

1. Unique identification code of the product-type:

**Briton 9963 Electrically Powered Hold Open/Free-swing Door Closer.**

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR:

**Briton 9963/01 & Briton 9963/66**

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

**For use on fire and smoke compartmentation doors**

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

**Allegion  
Bescot Crescent  
Walsall  
WS1 4DL**

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

**N/A**

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

**System 1**

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

**EN 1155: 1997: + A1: 2002  
Notified testing laboratory No.1121 performed the type testing and issued test reports.**

8. European Technical Assessment:

**N/A**

9. Declared performance

<b>Essential characteristics</b>	<b>Performance</b>	<b>Harmonised technical specification</b>
<b>Ability to release</b>		
<b>5.1.2 release from any angle</b>	<b>Pass</b>	
<b>5.1.3 Not possible to inhibit the release</b>	<b>Pass</b>	
<b>5.1.4 Supply voltage</b>	<b>Pass</b>	
<b>5.1.5 External electrical connection</b>	<b>Pass</b>	
<b>5.1.6 Inlet for external wiring</b>	<b>Pass</b>	
		<b>EN 1155: 1997: + A1: 2002</b>

5.2.1 General 5.2.2 Electrical release 5.2.3 Door closing device EN 1154 requirements 5.2.4 Durability  5.2.5 Angle of hold open 5.2.6 Manual release 5.2.7 Continues Hold open 5.2.8 Overload performance 5.2.9 Delayed release 5.2.10 Electrical performance 5.2.11 Temperature Rise 5.2.12 Damage 5.2.13 Fire / smoke doors	Pass EN 1154 (See separate DOP for this element) 25000 electrical 25000 mechanical >65° >40Nm but <120Nm Pass Pass Pass Pass Pass Pass Grade 1	
<b>Essential characteristics</b>	<b>Performance</b>	<b>Harmonised technical specification</b>
<u>Durability of Ability to release</u> 5.2.14.1 corrosion 5.2.14.2 corrosion  <u>Dangerous Substances</u> <u>Annex ZA3</u>	Grade 3 (96 hours) Pass  If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in the hinge do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)	EN 1155: 1997: +A1: 2002

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.  
Signed for and on behalf of the manufacturer by:

Chris Crampton  
Controller - Unitary EMEIA, Finance and Accounting



Allegion,  
Bescot Crescent,  
Walsall,  
WS1 4DL

02<sup>nd</sup> December 2013