


12MM COPPER	•	•	•	•
160MM COPPER	•	•	•	•
22MM MILD STEEL	•	•	•	•
160MM MILD STEEL	•	•	•	•
12MM POLYBUTYLENE	•	•	•	•
28MM POLYBUTYLENE	•	•	•	•
55MM PVC			•	
82MM PVC	•	•		•
110MM PVC	•	•		•
160MM PVC				•

Installation


1

CAREFULLY CUT THERMAL FIRE PS TO
REQUIRED LENGTH




2

IF NECESSARY MAKE SINGLE SLIT ALONG
SLEEVE LENGTH TO ALLOW FITTING AROUND
INSTALLED




3

FIT SLEEVE AROUND PIPE AND RESEAL THE
CUT WITH REPAIR TAPE



4

SLIDE SLEEVE ALONG PIPE AND INTO CAVITY
AND TAPE SLEEVE TO EXISTING INSULATION
IF REQUIRED



Please note : for irregular holes or gaps of greater than 15mm around the pipe sleeve fill with mortar, mastic or similar. Smaller gaps can be filled with Astro if required

Compliance

Astro Pipe Sleeves are manufactured in the EU, meeting the highest quality standard in compliance with ISO EN 9001:2000 . For fire test certification contact Astroflame Fireseals technical department.

Fire Test And Assessment Reports

BS Standard 476 part 20/22 2 Hour rated at Chiltern International Fire. 132 minutes integrity and insulation.

Storage And Disposal

For long term storage and ease of installation, it is recommended that the product should be stored indoors. No shelf life is given as this product will not deteriorate in storage.

For additional testing, certification or technical information please contact ASTROFLAME FIRESEALS LTD.

Issue 08/03

As part of our policy of ongoing improvements, we reserve the right to modify, alter or change product specifications without giving notice. Product illustrations are representations only. All information contained in this document is provided for guidance only, and as ASTROFLAME FIRESEALS LTD has no control over the installation methods of the products, or of the prevailing site conditions, no warranties expressed or implied are intended to be given as to the actual performance of the products mentioned or referred to, and no liability whatsoever will be accepted for any loss, damage or injury arising from the use of the information given of products mentioned or referred to herein.

The above information to the best of our knowledge is true and accurate and based upon current test data and is supplied for your guidance only. Customers should satisfy themselves to the suitability of the product in its intended use and no guarantee is given or implied since the conditions of actual use are beyond our control. ASTROflame (Fireseals) Ltd, disclaim any liability for loss, damage or other expense arising from the use of information, data or products mentioned or referred to and reserve the right to change any details or specifications without notice.

Astroflame (Fire Seals) Ltd. Intumescent House
Unit 8, The IO Centre, Stephenson Road, Segensworth
FAREHAM, ENGLAND PO15 5RU

tel 0800 023 2482
(01329 844500)

fax 0800 023 2483
(01329 844600)

intl
tel +44 1329 844500

fax +44 1329 844600

email