

Fire Trunking Sleeve - Installation Guide



Introduction

The purpose of this document is to give guidance to approved contractors and suppliers who are engaged in the fire stopping of service penetrations in fire rated structures using the Astro FT Fire Trunk Sleeve.

All service holes through floors and compartment walls must be fire stopped to prevent the passage of fire, smoke and hot gases.

Prevent the spread of fire, smoke and hot gases through a building by containing it in the compartment of origin.

Maintain the integrity of escape routes from a building.

Reduce loss or damage to property from the effect of fire and smoke.

Maintain pressure differential between compartments and ventilation channels.





The Astro FT Fire Trunking Sleeve

The Astroflame range of Astro FT Fire Trunking Sleeves are intended for use where plastic trunking passes through a fire rated wall. The sleeve reinstates the fire rating of the wall which would otherwise be lost.

In the event of a fire, the Astro FT Trunk Sleeve expands with the heat, crushing the trunking and closing off the hole to the fire for at least 2 hours.

The FT Trunk Sleeves are available to fit common sizes of plastic trunking and are suitable for retro fitting with access only required from one side. They are suitable for use with plastic trunking or can be used with cabling passed directly through the sleeve. 25mm thick wall

Installation



Astro FT Trunk Sleeve is manufactured in the EU, meeting the highest quality standard in compliance with ISO EN 9001:2000 . For fire test certification contact Astroflame Fireseals technical department.

Fire Tests

Tested to BS476 Part 22

Storage And Disposal

Astro FT Fire Trunk Sleeve should be stored indoors. No shelf life is given as this product will not deteriorate in storage.

For additional testing, certification or technical information please contact ASTROFLAME FIRESEALS LTD.

Issue 04/06

As part of our policy of ongoing improvements, we reserve the right to modify, alter or change product specifications without giving notice. Product illustrations are representations only. All information contained in this document is provided for guidance only, and as ASTROFLAME FIRESEALS LTD has no control over the installation methods of the products, or of the prevailing site conditions, no warranties expressed or implied are intended to be given as to the actual performance of the products mentioned or referred to, and no liability whatsoever will be accepted for any loss, damage or injury arising from the use of the information given of products mentioned or referred to herein.

The above information to the best of our knowledge is true and accurate and based upon current test data and is supplied for your guidance only. Customers should satisfy themselves to the suitability of the product in its intended use and no guarantee is given or implied since the conditions of actual use are beyond our control. ASTROflame (Fireseals) Ltd, disclaim any liability for loss, damage or other expense arising from the use of information, data or products mentioned or referred to and reserve the right to change any details or specifications without notice.

Astroflame (Fire Seals) Ltd. Intumescent House
Unit 8, The IO Centre, Stephenson Road, Segensworth
FAREHAM, ENGLAND PO15 5RU

tel 0800 023 2482
(01329 844500)

fax 0800 023 2483
(01329 844600)

intl
tel +44 1329 844500

fax +44 1329 844600

email