

CERTIFIKAT

No. SC0498-09

Document cabinets

Holder/Issued to/Manufacturer

Gunnebo Bazancourt, 15, rue Fichet-Bauche, FR-51 110 BAZANCOURT, France

Product name

Chubbsafes Trident series For details, see attached appendix

Product information

See attached appendix

Fire resistance class

NT FIRE 017 - 60 Paper

Performance specification

NT FIRE 017 and SP's certification rules for fire resisting storage cabinets, SPCR 002.

Marking

Marking in the cabinet shall show the name of the product, its fire resistance class, its serial number, the number of this certificate and SP's **P**-symbol.

Validity

This certificate is valid until not longer than 30th June 2019.

Miscellaneous

The manufacturer's in-house inspection is under surveillance by SP in accordance with section 4 and 5 of SPCR 002. Other terms and conditions are set out in section 6 of SPCR 002. This is the third, extended, issue of this certificate.

Borås 30th June 2014

SP Technical Research Institute of Sweden

Certification

Lennart/Månsson Certification Manager Martin Tillander Certification Officer





CERTIFIKAT

No. SC0498-09 - Appendix 1

Dated 30th June 2014

Product information

Table 1 dimensions

Cabinet	Externa	External dimensions (mm)			Internal dimensions (mm)		
Chubbsafes Trident							
Grade III - IV - V - VI				2 8 2			
	width	height	depth	width	height	depth	
model 110	730	790	560	560	620	320	
model 140	730	790	640	560	620	400	
model 170	730	920	640	560	750	400	
model 210	730	920	740	560	750	500	
model 310	730	1270	740	560	1100	500	
model 420	810	1470	740	640	1300	500	
model 540	810	1850	740	640	1680	500	
model 600	880	1850	740	710	1680	500	
model 840	1250	1890	690	1080	1720	450	
model 910	1250	1850	740	1080	1680	500	
model 1120	1500	1850	740	1330	1680	500	

Table 2, weights

Cabinet	Weight (kg)						
Chubbsafes Trident	Grade III	Grade IV	Grade V	Grade VI			
model 110	540	560	595	635			
model 140	600	615	655	700			
model 170	670	695	740	790			
model 210	745	775	825	880			
model 310	970	1005	1075	1150			
model 420	1180	1225	1310	1400			
model 540	1450	1500	1600	1710			
model 600	1530	1590	1695	1810			
model 840	1960	2020	2150	2300			
model 910	1990	2060	2195	2350			
model 1120	2295	2380	2535	2710			

Models 110-600 have single door, models 840-1120 have double doors.

The fire resistance performance of the cabinets are not maintained if holes are drilled through the inner or outer steel plates of the wall or door, example through the tubes.



Appendix page 1(1) Sign: Mars

SP Technical Research Institute of Sweden