Composite Fire Extinguisher P50F2/M



P50F2/M BSX-ASX Foam



The foam fire extinguisher has excellent firefighting capabilities making it effective on Class A materials fuelled by wood, paper and textiles as well as Class B fires fuelled by paints, solvents, oils and petrochemical products.

The extinguisher has also passed the EN3 test for use on live electrical equipment up to 1000V at a distance of 1m. The operational temperature range is from $+5^{\circ}$ C to $+60^{\circ}$ C.

Marine Model Available.

Features

- Manufactured in Great Britain
- 10 year operational corrosion guarantee
- 10 year quality assurance on material defects and workmanship
- 20 year life cycle
- No service contract required
- Requires only one manufacturer overhaul at 10 years
- A yearly visual maintenance inspection, checking indicators with the magnet
- A Schrader valve is fitted on marine models allowing easy refilling on-board vessel
- Recyclable
- Super strength Aramid (Kevlar®) type material yarn
- Lightweight for ease of operation
- Kitemark, PED, MED and EN3 approved
- Manufacturer ensures safe disposal of contents when required
- UV protection of the outer casing
- QA laser serial number on outer casing
- Operating valve nickel plated brass
- World recognised patented design
- Main approvals and certifications as below









TECHNICAL SPECIFICATION									
Model	Capacity (Litres)	Fire Rating	Full Weight (Kgs)	Temp Range	Operating Pressure (Bar) @ 20°C	Discharge Duration (Secs)	Discharge Range (M)	Diameter (mm)	Height (mm)
P50F2	2	8A/55B	2.8	+5° to + 60°C	12	18	3	125	410

SPECIFICATIONS			
Operating Pressure @ 20°C	12bar		
Test Pressure (PT)	22bar		
Maximum Allowable Pressure (PS)	15.38bar		
Minimum Burst Pressure	55bar		
Cylinder Material	HDPE with Aramid Winding (Kevlar®)		
Operating Head Material	Brass - C3771 - Nickel Plated		
Nozzle	Nylon		

COMPONENT PARTS				
Item	Description	Part No.		
А	Headcap Assembly	P50-HC-ASS2		
В	Nozzle	P50-2KGNOZZ-C		
С				
D	Transport/Wall Bracket	P502KG- BRACKET		
-	2lt Foam Refill 1.5%	AFFT02		

The extinguisher maintenance programme is a simple process which staff members can easily carry out.

If an indicator is in the **RED** segment return to manufacturer or appointed distributor.

Remove any dust with a clean cloth. Turn upside down to inspect base and locate testing magnet.

Check date is within 10 year operational lifespan (colour coded stud in base gives year of manufacture (F). At 10 years return to manufacturer or distributor for manufacturers overhaul to extend the lifespan by a further 10 years.

Check the tamper seal is in place (E). If tamper seal is missing, contact manufacturer or distributor.

Check both indicators with a magnet to confirm operation (G). Moving magnet from side to side needle should move then return to **GREEN** segment. Return magnet to base.

Record yearly inspection date into logbook and mark extinguisher body with permanent marker pen.

INSTALLATION DATE				
Year of Inspection	Examiners Signature			
	IDIE			
SA	MPLE			

YEAR OF MANUFACTURE COLOUR CODES STUD CHART				
GREY	2017			
BROWN	2018			
ORANGE	2019			
PURPLE	2020			
YELLOW	2021			
GREEN	2022			
RED	2023			
BLUE	2024			
WHITE	2025			
BLACK	2026			

FROST PROTECTION TO -5°C IS AVAILABLE



