



Chaussée de Vilvoorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel: 32 (0)2 264 03 60
Fax: 32 (0)2 268 89 58
http://www.apragaz.com
info@apragaz.com



NOTIFIED BODY EC TYPE EXAMINATION CERTIFICATE		Certificate N° 13/UK/3059-0-REV 0 Page 1/3
In accordance with module B of the Marine Equipment Directive 96/98/EC as amended		
Manufacturer	Name	Britannia Fire Ltd.
	Address	Ashwellthorpe Industrial Estate Norfolk NR16 1ER United Kingdom
<p>Concerned Equipment: Item n° A.1 / 3.2 Portable Fire Extinguishers Item n° A.1/ 3.52 Mobile Fire Extinguishers (existing ranges) The details are mentioned in appendixes 1 to 2 of the present certificate.</p>		
<p>The manufacturer is allowed to affix the marine CE mark  followed with our notified body identification n° 0029 to the approved equipment in the conditions described in article 11 of the Directive, only if the requirements stated in Module D are fully complied with.</p> <p style="text-align: center;">The approval is valid until 04/03/2018</p>		
<p>APRAGAZ, acting within the scope of its notification for the purpose of the European Council Directive 96/98/EC, certifies that the types of these extinguishing systems conforms to the relevant requirements of the pertinent EN3 Standards and the Marine Equipment Directive 96/98 as amended on basis of the documentation and samples supplied for review and approval.</p>		
Date : 04/03/2013	Name : Ch. Leplat	Position General Manager
Notified body identification number :	0029	Signature 
Notified body stamp :	APRAGAZ Belgium Inspecting Authority	
Notified body reference :	P13576/009	



Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel: 32 (0)2 264 03 60
Fax: 32 (0)2 268 89 58
http://www.apragaz.com
info@apragaz.com



NOTIFIED BODY EC TYPE EXAMINATION CERTIFICATE
In accordance with module B of the Marine Equipment Directive
96/98/EC as amended

Certificate N°
13/UK/3059-0-REV 0
Appendix 1
Page 2/3

Summary Table According Technical Files n° OWBODYL, OWBODYM, OWBODYXL, BC5

Portable Fire Extinguishers		Test report EN3.7	Fire Classes	Operation temperature range	Working Pressure at T° max	Test Pressure (PT)
Mark	TYPE capacity					
BAF9MED	9 L AFFF	EP005107BAF9	13A/183B	+5°C/+60 °C	18 bar	27 bar
BT9MED	9 L AFFF	EP005107BT9	21A/183B	+5°C/+60 °C	18 bar	27 bar
BA6MED	6kg ABC Powder	EP005107BA6	27A/183B	-20°C/+60 °C	18 bar	27 bar
B6MED	6 kg ABC Powder	EP005107B6	183B	-20°C/+60 °C	18 bar	27 bar
BA9MED	9kg ABC Powder	EP005107BA9	34A/233B	-20°C/+60 °C	18 bar	27 bar
BS12MED	12 kg BC Powder	EP005107BS12	233B	-20°C/+60 °C	18 bar	27 bar
BA12MED	12 kg ABC Powder	EP005107BA12	43A/233B	-20°C/+60 °C	18 bar	27 bar
BW9MED	9 L Water	EP005107BW9	21A	+5°C/+60 °C	18 bar	27 bar
BC5MED	CO2	EP005107BC5	70B	-20°C/+60 °C	169.3bar	250 bar

Date : 04/03/2013

Name : Ch. Leplat

Position **General Manager**

Notified body identification
number :

0029


Signature

Notified body stamp :

APRAGAZ
Belgium
Inspecting
Authority

Notified body reference :

P13576/009



Chaussee de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel: 32 (0)2 264 03 60
Fax: 32 (0)2 268 89 58
http://www.apragaz.com
info@apragaz.com



NOTIFIED BODY EC TYPE EXAMINATION CERTIFICATE In accordance with module B of the Marine Equipment Directive 96/98/EC as amended	Certificate N° 13/UK/3059-0-REV 0 Appendix 2 Page 3/3
--	--

Summary Table According Technical Files n° BODIM - BODIL (Blazex Fire Extinguishers BX), BOD14WP - BOD14WF - BOD20WF (Norfolk Range NR)

Portable Fire Extinguishers		Test report EN3.7	Fire Classes	Operation temperature range	Working Pressure at T° max	Test Pressure (PT)
Mark	TYPE capacity					
BXP6MED	6 kg ABC Powder	285/4472321-XAS6	27A/183B	-20°C/+60 °C	18 bar	27 bar
BXP9MED	9kg ABC Powder	285/4472321-XAS9	34A/233B	-20°C/+60 °C	18 bar	27 bar
BXW9MED	9 L Water	285/4472321-XWS9	21A	+5°C/+60 °C	18 bar	27 bar
BXF9MED	9 L AFFF	285/4472321-XTS9	21A/183B	+5°C/+60 °C	18 bar	27 bar
NRA50	50kg ABC Powder	2381/7391607-NRA50	IB	-30°C/+60 °C	14 bar	21 bar
NRAF45	45 l AFFF	2381/7391607-NRAF45	II B	+5°C/+60 °C	14 bar	21 bar
NRAF135	135 l AFFF	2381/7391607-NRAF135	IV B	+5°C/+60 °C	18 bar	27 bar

Date : 04/03/2013

Name : Ch. Leplat

Position **General Manager**

Notified body identification
number :

0029

Signature

Notified body stamp :

APRAGAZ
Belgium
Inspecting
Authority

Notified body reference :

P13576/009