



EC CERTIFICATE

Notified Body No. 0843

CPR Notified Body, UL International (UK) Ltd., Kingsland Business Park, Unit 1-3 Horizon, Wade Rd, Basingstoke RG24 8AH, United Kingdom

Certificate of constancy of performance 0843-CPR-0560

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Astro PFP FR Pipe Wrap

Penetration Seal Classified for use in flexible & solid walls and solid floors

A pipe closure device used to form penetration seals where combustible pipes and insulated metal pipes penetrate walls and floors. Astro PFP FR Pipe Wrap is supplied in Polyethylene bags size according to pipe diameter. The wrap is wrapped around the pipe and pushed into the aperture in the separating element/ Astro PFP FR Board or cast in with Astro PFP FR EX Mortar.

placed on the market under the name or trade mark of

Astroflame Fireseals Ltd
Unit 8 The IO Centre, Stephenson Road, Segensworth, Fareham,
Hampshire, PO15 5RU
and produced in the manufacturing plant(s)

A/003

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the

ETA 20/0198, issued on 20/03/2020

and

EAD 350454-00-1104, September 2017

under system AVCP 1 for the performance set out in the ETA are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 20th March 2020 and will remain valid as long as neither the ETA, the EAD, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body..

20th March 2020

Mr. Chris Johnson, Staff Engineer



EC CERTIFICATE

Notified Body No. 0843

CPR Notified Body, UL International (UK) Ltd., Kingsland Business Park, Unit 1-3 Horizon,
Wade Rd, Basingstoke RG24 8AH, United Kingdom

Annex: Detailed information sheet

Certificate Number: 0843-CPR-0560

Product/Device description: Astro PFP FR Pipe Wrap

Applicant designation: Astroflame Fireseals Ltd, Unit 8 The IO Centre, Stephenson Road, Segensworth,
Fareham, Hampshire, PO15 5RU

Product Information

Astro PFP FR Pipe Wrap

The referenced product complies with:

A – All the relevant requirements as per ETA 20/0198

ETA issue dates:

ETA 20/0198, issued 20/03/2020

20th March 2020

Mr. Chris Johnson, Staff Engineer