



Central Unit configuration settings

The following table shows the configurable items that can be changed in the Central Unit software menus

NOTE: PLEASE MAKE A NOTE OF THE NEW CONFIGURATION SETTING IN THE NEW SETTING COLUMN NEXT TO EACH CONFIGURATION OPTION.

| Item | Default setting | New setting | Comment |
|---------------------------|-----------------|-------------|--|
| Global Evacuation mode | Evacuate | | Each alarm has its own evacuation mode. |
| Number of attached sensor | 2 | | A COMMS fault will occur if the correct number of sensors have not attached. |
| Relay fail-safe mode | Fail-safe | | Default applies to both relays, but each can be set independently |