

## DECLARATION OF PERFORMANCE

According to Annex III of the Regulation (EU) Nr.305/2011 (Construction Products Regulation)



### ASTRO X SERIES®

#### PILLOW

2531-CPR-CXO10300

**1. Unique identification code of product-type:**

XSPIL

**2. Intended use/es:**

For fire compartmentation and / or fire protection or performance, ETA-21/0317 and EAD 350454-00-1104.

**3. Manufacturer:**

Astroflame Fireseals Ltd, Unit 8, The I O Centre, Stephenson Road, Segensworth, Fareham Hampshire, PO15 5RU

**4. Not applicable**

**5. System/s of AVCP:** AVCP - System 1

**6b. European Assessment Document:** EAD 350454-00-1104 - September 2017

**European Technical Assessment:** ETA-21/0317

**Technical Assessment Body:** ETA Danmark

**Notified Body/ies:** 2531

**7. Declared performance:**

Essential Characteristics	Performance/Harmonised technical specification
Reaction to Fire	Class F according to EN13501-1
Reaction to Fire	Resistance to fire performance & field of application in accordance with EN13501-2 See ETA 21/0317 clause 3.2 - Annex C
Air Permeability	Tested in accordance with EN 1026, See ETA 21/0317 Clause 3.3
Dangerous Substances	See ETA-21/0317 Clause 3.5
Airborne Sound Insulation	Tested in accordance with EN ISO 10140-2:2010 & EN ISO 717-1 See ETA 21/0317 Clause 3.9 - $R_w (C;Ctr) = 33 (G;-2)$ dB
Service & Durability	Z <sup>1</sup> (0/+40°C) intended for use at internal conditions with high humidity (85%) in accordance with EOTA technical documents TR024
Other	Not applicable/No performance determined

**8. Appropriate Technical Documentation and/or Specific Technical Documentation:** ETA 21/0317

Link to the online copy of the declaration of performance: [www.astroflame.com](http://www.astroflame.com)

Signed on the behalf of the manufacturer by:

P.Kieser - Managing Director 17/02/2022

(Place of signature : Segensworth Fareham)

C.Dickens - Technical Managing 17/02/2022