



BD/BCO/RF10-PRO

CONNECTED CARBON MONOXIDE ALARM

10 YEAR BATTERY INCLUDED

PRODUCT FEATURES:

- **Full Home Interlink:** Connect up to 20 alarms, when one goes off all alarms trigger
- **10 Year Sealed Battery:** The battery lasts for the life of the alarm
- **Easy Installation:** Quick and hassle free setup
- **Low Maintenance:** Reliable with minimal upkeep
- **Protect Your Family:** Detects the “Silent Killer” carbon monoxide
- **Electrochemical Sensing Technology:** Detects carbon monoxide with precision and minimal false alarms
- **Sleek, Low Profile Design:** Discreet look to suit any space
- **Insect Proof:** Reduced False Alarms



DESCRIPTION:

The **Black + Decker Connected Carbon Monoxide Alarm** provides advanced carbon monoxide detection, a 10 year sealed battery and RF interconnectivity for full home safety. It is interconnectable with up to 20 units and installed with a sealed 10 year lithium battery. With easy installation, a hush function and a loud 85dB alarm, it ensures long term reliability and peace of mind.

TECHNICAL SPECIFICATION:

Ambient Operating Temperature:	0°C - 40°C
Ambient Operating Humidity:	0 to 90%
CO Alarm Activation Threshold:	50ppm (60-90 mins), 100ppm (10-40 mins), 300ppm (<3 mins)
Power Source:	10 Year Lithium Battery
Housing Material:	Fire Retardant ABS
Weight:	66g
Alarm Sounder Level:	85dB at 3 metres
Max RF Distance:	Open Area 80m, Enclosed Area 30m
Transmit & Recieve Frequency:	868MHz
Approved To:	BS EN 50291-1:2018
Designed For Installation To:	BS EN 50292:2023
Max Interconnected Units:	20
Max RF Connected Units:	20
Storage Temperature	-10 to 50°C
Storage Humidity:	0-90%RH(non-condensing)

**All information is subject to change and should be verified before any critical action.*






BD/BCO/RF10-PRO

CONNECTED CARBON MONOXIDE ALARM

10 YEAR BATTERY INCLUDED

LINE DRAWINGS:



INSTALLATION LOCATIONS:



KITCHENS



GAS BOILERS



GAS FIREPLACE



BOATS



CARAVANS



TENTS



KM 792791
BS EN 50291-1:2018

**All information is subject to change and should be verified before any critical action.*

